


ANNUAL WATER QUALITY REPORT

Water testing performed in 2007



CITY OF GROSSE
POINTE FARMS

PWS ID#: 0002890

Meeting the Challenge

We are once again proud to present to you our annual water quality report. This edition covers all testing completed from January 1 through December 31, 2007. Over the years, we have dedicated ourselves to producing drinking water that meets all state and federal drinking water standards. We continually strive to adopt new and better methods for delivering the best quality drinking water to you. As new challenges to drinking water safety emerge, we remain vigilant in meeting the challenges of source water protection, water conservation and community education while continuing to serve the needs of all our water users.

Please share with us your thoughts about the information in this report. After all, well-informed customers are our best allies.

Important Health Information

Some people may be more vulnerable to contaminants in drinking water than the general population. Immunocompromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants may be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. The U.S. EPA/CDC (Centers for Disease Control and Prevention) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline at (800) 426-4791.

Information on the Internet

The U.S. EPA Office of Water (www.epa.gov/watrhome) and the Centers for Disease Control and Prevention (www.cdc.gov) Web sites provide a substantial amount of information on many issues relating to water resources, water conservation, and public health. Also, the Michigan Department of Environmental Quality has a Web site (www.michigan.gov/deq) that provides complete and current information on water issues in Michigan, including valuable information about our watershed.

Where Does My Water Come From?

The City of Grosse Pointe Farms draws water from Lake St. Clair at an intake station shared with the City of Highland Park. At the water treatment plant, a variety of treatment processes occur. For example, water is settled and filtered for impurities and chlorine is added to disinfect the water before it reaches your tap. Also, other chemicals are added that control contaminants such as lead and copper.

“WELL-INFORMED CUSTOMERS ARE OUR BEST ALLIES.”

Community Participation

We have regular council meetings where you can participate and voice your concerns about your drinking water. We meet at City Hall, 90 Kerby Road, Grosse Pointe Farms, Michigan. Meeting times are available on our Web site at www.ci.grosse-pointe-farms.mi.us or you can call (313) 885-6600 for additional information.

Source Water Assessment

A source water assessment has been completed for our water system. Our source water has a classification of high susceptibility to contamination. This susceptibility rating does not imply poor water quality; rather, it signifies the system's potential to become contaminated. To review the Source Water Assessment please contact Scott Homminga at (313) 885-6600.

Tap vs. Bottled

Thanks in part to aggressive marketing, the bottled water industry has successfully convinced us all that water purchased in bottles is a healthier alternative to tap water. However, according to a four-year study conducted by the Natural Resources Defense Council, bottled water is not necessarily cleaner or safer than most tap water. In fact, about 25% of bottled water is actually just bottled tap water (40% according to government estimates).

The Food and Drug Administration is responsible for regulating bottled water, but these rules allow for less rigorous testing and purity standards than those required by the U.S. EPA for community tap water. For instance, the high mineral content of some bottled waters makes them unsuitable for babies and young children. Further, the FDA completely exempts bottled water that's packaged and sold within the same state, which accounts for about 70% of all bottled water sold in the United States.

People spend 10,000 times more per gallon for bottled water than they typically do for tap water. If you get your recommended eight glasses a day from bottled water, you could spend up to \$1,400 annually. The same amount of tap water would cost about 49 cents. Even if you installed a filter device on your tap, your annual expenditure would be far less than what you'd pay for bottled water.

For a detailed discussion on the NRDC study results, check out their Web site at www.nrdc.org/water/drinking/bw/exesum.asp.



Questions?

For more information about this report, or for any questions relating to your drinking water, please call Scott Homminga, Water Superintendent, at (313) 885-6600.

Substances That Might be in Drinking Water

To ensure that tap water is safe to drink, the U.S. EPA prescribes regulations limiting the amount of certain contaminants in water provided by public water systems. U.S. Food and Drug Administration regulations establish limits for contaminants in bottled water, which must provide the same protection for public health. Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of these contaminants does not necessarily indicate that the water poses a health risk.

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals, in some cases, radioactive material; and substances resulting from the presence of animals or from human activity. Substances that may be present in source water include:

Microbial Contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, or wildlife;

Inorganic Contaminants, such as salts and metals, which can be naturally occurring or may result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming;

Pesticides and Herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses;

Organic Chemical Contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and may also come from gas stations, urban stormwater runoff, and septic systems;

Radioactive Contaminants, which can be naturally occurring or may be the result of oil and gas production and mining activities.

For more information about contaminants and potential health effects, call the U.S. EPA's Safe Drinking Water Hotline at (800) 426-4791.



Is it Safe to Drink Water From a Garden Hose?


Substances used in vinyl garden hoses to keep them flexible can get into the water as it passes through the hose. These chemicals are not good for you, nor are they good for your pets. Allow the water to run for a short time in order to flush the hose before drinking or filling your pet's drinking containers. There are hoses made with "food-grade" plastic that will not contaminate the water. Check your local hardware store for this type of hose.

How Long Can I Store Drinking Water?

The disinfectant in drinking water will eventually dissipate even in a closed container. If that container housed bacteria prior to filling up with the tap water the bacteria may continue to grow once the disinfectant has dissipated. Some experts believe that water could be stored up to six months before needing to be replaced. Refrigeration will help slow the bacterial growth.

Should I Put a Brick in My Toilet Tank to Save Water?

Toilet flushing uses a lot of water - about 40% of a household's total water usage. Putting something in the toilet tank that takes up space, like a toilet dam or a water filled jug, is a good idea. But putting a brick in the tank is not so, as bricks tend to crumble and may damage your toilet.



Fixtures With Green Stains

A green or blue-green stain on kitchen or bathroom fixtures is caused by tiny amounts of copper that dissolve in your home's copper plumbing system when the water sits unused overnight. Copper staining may be the result of a leaky faucet or a faulty toilet flush valve, so be sure your plumbing is in good working order.

Copper stains may also be caused by overly hot tap water. Generally speaking, you should maintain your water temperature at a maximum of 120 degrees Fahrenheit. You should consult the owner's manual for your heater or check with your plumber to determine your current heat setting. Lowering your water temperature will reduce the staining problem and save you money on your energy bill.

Also keep in mind that a tap that is used often throughout the day usually will not produce copper stains, so if you flush the tap for a minute or so before using the water for cooking or drinking, copper levels will be reduced.

Lead and Drinking Water



If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The City of Grosse Pointe Farms is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at www.epa.gov/safewater/lead.

Contamination from Cross-Connections



Cross-connections that contaminate drinking water distribution lines are a major concern. A cross-connection is formed at any point where a drinking water line connects to equipment (boilers), systems containing chemicals (air conditioning systems, fire sprinkler systems, irrigation systems) or water sources of questionable quality. Cross-connection contamination can occur when the pressure in the equipment or system is greater than the pressure inside the drinking water line (backpressure). Contamination can also occur when the pressure in the drinking water line drops due to fairly routine occurrences (main breaks, heavy water demand) causing contaminants to be sucked out from the equipment and into the drinking water line (backsiphonage).

Outside water taps and garden hoses tend to be the most common sources of cross-connection contamination at home. The garden hose creates a hazard when submerged in a swimming pool or when attached to a chemical sprayer for weed killing. Garden hoses that are left lying on the ground may be contaminated by fertilizers, cesspools or garden chemicals. Improperly installed valves in your toilet could also be a source of cross-connection contamination.

Community water supplies are continuously jeopardized by cross-connections unless appropriate valves, known as backflow prevention devices, are installed and maintained. We have surveyed all industrial, commercial, and institutional facilities in the service area to make sure that all potential cross-connections are identified and eliminated or protected by a backflow preventer. We also inspect and test each backflow preventer to make sure that it is providing maximum protection.

For more information, review the Cross-Connection Control Manual from the U.S. EPA's Web site at www.epa.gov/safewater/crossconnection.html. You can also call the Safe Drinking Water Hotline at (800) 426-4791.

Sampling Results

During the past year we have taken hundreds of water samples in order to determine the presence of any radioactive, biological, inorganic, volatile organic or synthetic organic contaminants. The table below shows only those contaminants that were detected in the water. Although all of the substances listed here are under the Maximum Contaminant Level (MCL), we feel it is important that you know exactly what was detected and how much of the substance was present in the water.

The state requires us to monitor for certain substances less than once per year because the concentrations of these substances do not change frequently. In these cases, the most recent sample data are included, along with the year in which the sample was taken.

REGULATED SUBSTANCES

| SUBSTANCE (UNIT OF MEASURE) | YEAR SAMPLED | MCL [MRDL] | MCLG [MRDLG] | AMOUNT DETECTED | RANGE LOW-HIGH | VIOLATION | TYPICAL SOURCE |
|--|--------------|------------|--------------|-----------------|----------------|-----------|---|
| Barium (ppm) | 2004 | 2 | 2 | 0.02 | NA | No | Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits |
| Chlorine (ppm) | 2007 | [4] | [4] | 0.53 | 0.18–1.05 | No | Water additive used to control microbes |
| Fluoride (ppm) | 2007 | 4 | 4 | 0.95 | NA | No | Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories |
| Haloacetic Acids [HAA] (ppb) | 2007 | 60 | NA | 8.9 | ND–12 | No | By-product of drinking water disinfection |
| Selenium (ppb) | 2004 | 50 | 50 | 2 | NA | No | Discharge from petroleum and metal refineries; Erosion of natural deposits; Discharge from mines |
| TTHMs [Total Trihalomethanes] (ppb) | 2007 | 80 | NA | 18.5 | 3.9–18 | No | By-product of drinking water chlorination |
| Total Organic Carbon (ppm) | 2007 | TT | NA | 1.19 | 0.86–1.19 | No | Naturally present in the environment |
| Turbidity¹ (NTU) | 2007 | TT | NA | 0.29 | 0.09–0.29 | No | Soil runoff |
| Turbidity (Lowest monthly percent of samples meeting limit) | 2007 | TT | NA | 100 | NA | No | Soil runoff |

Tap water samples were collected from 20 sample sites throughout the community

| SUBSTANCE (UNIT OF MEASURE) | YEAR SAMPLED | ACTION LEVEL | MCLG | AMOUNT DETECTED (90TH% TILE) | SITES ABOVE ACTION LEVEL | VIOLATION | TYPICAL SOURCE |
|-----------------------------|--------------|--------------|------|------------------------------|--------------------------|-----------|--|
| Copper (ppm) | 2007 | 1.3 | 1.3 | 0.292 | 0 | No | Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives |
| Lead (ppb) | 2007 | 15 | 0 | 4.9 | 1 | No | Corrosion of household plumbing systems; Erosion of natural deposits |

UNREGULATED SUBSTANCES

| SUBSTANCE (UNIT OF MEASURE) | YEAR SAMPLED | AMOUNT DETECTED | RANGE LOW-HIGH | TYPICAL SOURCE |
|-----------------------------|--------------|-----------------|----------------|-----------------------------|
| Sodium (ppm) | 2007 | 7 | NA | Erosion of natural deposits |

¹ Turbidity is a measure of the cloudiness of the water. It is monitored because it is a good indicator of the effectiveness of the filtration system.

Definitions

AL (Action Level): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

MCL (Maximum Contaminant Level): The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

MCLG (Maximum Contaminant Level Goal): The level of a contaminant in drinking water below which there is no known or expected risk to health.

MCLGs allow for a margin of safety.

MRDL (Maximum Residual Disinfectant Level): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

MRDLG (Maximum Residual Disinfectant Level Goal): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

NA: Not applicable

ND (Not detected): Indicates that the substance was not found by laboratory analysis.

NTU (Nephelometric Turbidity Units): Measurement of the clarity, or turbidity, of water. Turbidity in excess of 5 NTU is just noticeable to the average person.

ppb (parts per billion): One part substance per billion parts water (or micrograms per liter).

ppm (parts per million): One part substance per million parts water (or milligrams per liter).

TT (Treatment Technique): A required process intended to reduce the level of a contaminant in drinking water.